

ORDINANCE

BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF CHICAGO:

SECTION 1. Section 13-196-204 of the Municipal Code of the City of Chicago is hereby amended by deleting the language stricken through, and by inserting the language underscored, as follows:

13-196-204 Voice communication systems in existing buildings.

(A) Subject to the exceptions listed below, no later than January 1, ~~2012~~ 2015, every existing building exceeding 80 feet in height above grade shall be equipped with the following: (i) a one-way voice communication system meeting the requirements of Section 13-76-050(b); and (ii) a two-way voice communication system meeting the requirements of Section 13-76-050(a); provided, however, that a telephone or other two-way communication system connected to an approved station, and installed pursuant to and in accordance with Option 2 of Section 13-196-084(a), shall be deemed to satisfy the requirements of item (ii) of this subsection.

(Omitted text is unaffected by this ordinance)

SECTION 2. This ordinance shall take full force and effect upon its passage and publication.